

P.H. DIVISION, JAMUI
Test report of Water Quality Raw Water

Agency name- Mani Dweep Academy

Sample Collected by- Pawan Kumar Lab Assistant

Date of Sampling:-02.06.2023

Physico-Chemical and Bacteriological Parameters					PH	TDS	EC	TH	Ca	Mg	Cl	F _{RAW}	NO ₃	T.Coli	Remarks
Unit					-	mg/l	ymho/cm	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	MPN/100 ml	
Permissible Limit* in absence of alternate source					6.5-8.5	500	-	200	75	30	250	1.00	45	YES /NO	
					NR	2000	-	600	200	100	1000	1.50	NR		
Sl. No	Block	Panchyat	Habitation	Ward No	6	8	9	10	11	12	13	14	16	18	19
1	Jamui	Nagar Panchayat	Mani Dweep Acadwmy	-	7.0	242	372	76	34	10	48	0.54	8	NO	Safe

Note- Safe Drinking Water

A. Anand
02/06/2023
 Chemist/Lab Assistant
 P.H. Division, Jamui